

Commonwealth of Kentucky
Natural Resources and Environmental Protection Cabinet
Department for Environmental Protection
Division for Air Quality
803 Schenkel Lane
Frankfort, Kentucky 40601
(502) 573-3382

AIR QUALITY PERMIT

Permittee Name: East Kentucky Power Cooperative, Inc
Mailing Address: P.O. Box 707, Winchester, Kentucky 40392-0707

is authorized to operate an
electric power generating plant at Burnside, Kentucky

Source Name: John Sherman Cooper Power Station
Mailing Address: P.O. Box 707 Winchester, Kentucky 40392-0707
Source Location: State Highway 1247 South, Burnside

Permit Type: Federally-Enforceable
Review Type: Title V
Permit Number: V-97-044
Log Number: E936

Application Complete
Date: February 11, 1997
KYEIS ID #: 105-3460-0005
AFS Plant ID #: 21-199-00005
FINDS Number: KYD985079946
SIC Code: 4911

Region: South Central
County: Pulaski

Issuance Date: May 18, 1999
Expiration Date: May 18, 2004

John E. Hornback, Director
Division for Air Quality

TABLE OF CONTENTS

<u>SECTION</u>		<u>DATE OF ISSUANCE</u>	<u>PAGE</u>
SECTION A	PERMIT AUTHORIZATION	May 18, 1999	1
SECTION B	EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS	May 18, 1999	2
SECTION C	INSIGNIFICANT ACTIVITIES	May 18, 1999	15
SECTION D	SOURCE EMISSION LIMITATIONS AND TESTING REQUIREMENTS	May 18, 1999	18
SECTION E	SOURCE CONTROL EQUIPMENT OPERATING CONDITIONS	May 18, 1999	19
SECTION F	MONITORING, RECORD KEEPING, AND REPORTING REQUIREMENTS	May 18, 1999	20
SECTION G	GENERAL CONDITIONS	May 18, 1999	23
SECTION H	ALTERNATIVE OPERATING SCENARIOS	May 18, 1999	29
SECTION I	COMPLIANCE SCHEDULE	May 18, 1999	30

SECTION A - PERMIT AUTHORIZATION

Pursuant to a duly submitted application which was determined to be complete on February 11, 1997, the Kentucky Division for Air Quality hereby authorizes the operation of the equipment described herein in accordance with the terms and conditions of this permit. This permit has been issued under the provisions of Kentucky Revised Statutes Chapter 224 and regulations promulgated pursuant thereto.

The permittee shall not construct, reconstruct, or modify any emissions units without first having submitted a complete application and receiving a permit for the planned activity from the permitting authority, except as provided in this permit or in the Regulation 401 KAR 50:035, Permits.

Issuance of this permit does not relieve the permittee from the responsibility of obtaining any other permits, licenses, or approvals required by this Cabinet or any other federal, state, or local agency.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS

Emissions Unit 01 (01) - Indirect Heat Exchanger (Unit 1)

Description:

Pulverized coal-fired, dry-bottom, wall-fired unit equipped with electrostatic precipitator and low NO_x burners

Number two fuel oil used for startup and stabilization

Maximum continuous rating: 1080 mmBTU/hr

Construction commenced: 1965

Applicable Regulations:

Regulation 401 KAR 61:015, Existing indirect heat exchangers applicable to an emission unit with a capacity more than 250 MMBTU per hour and commenced before August 17, 1971. Regulation 7, Prevention and control of emissions of particulate matter from combustion of fuel in indirect heat exchangers.

1. Operating Limitations:

None

2. Emission Limitations:

- a) Pursuant to Regulation 401 KAR 61:015, Section 4 (4), and Regulation No. 7, particulate emissions shall not exceed 0.293 lb/MMBTU based on a three-hour average.
- b) Pursuant to Regulation 401 KAR 61:015, Section 4 (4), Regulation No. 7, emissions shall not exceed 40 percent opacity based on a six-minute average except that a maximum of 60 percent opacity is allowed for a period or aggregate of periods not more than six minutes in any 60 minutes during building a new fire, cleaning the firebox, or blowing soot.
- c) Pursuant to Regulation 401 KAR 61:015, Section 5 (1), sulfur dioxide emission shall not exceed 3.3 lbs/MMBTU based on a twenty-four-hour average.

3. Testing Requirements:

- a) The permittee shall submit a schedule within six months from the issuance date of this permit to conduct at least one performance test for particulate within one year following the issuance of this permit.
- b) If no additional stack tests are performed pursuant to Condition 4. d), the permittee shall conduct a performance test for particulate emissions within the third year of the term of this permit to demonstrate compliance with the applicable standard.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

c) The permittee shall determine the opacity of emissions from the stack by EPA Reference Method 9 annually, or more frequently if requested by the Division.

4. Specific Monitoring Requirements:

a) Pursuant to Regulation 401 KAR 61:005, Section 3 and Regulation 401 KAR 50:035, Section 7(1)(c), continuous emission monitoring systems shall be installed, calibrated, maintained, and operated for measuring sulfur dioxide emissions and either oxygen or carbon dioxide emissions. Or pursuant to Regulation 401 KAR 50:035, Section 7(1)(c) and Regulation 401 KAR 61:015, Section 6(6), monitoring of operations for sulfur dioxide emissions shall be conducted daily by fuel sampling and analysis of fuel as fired if the affected facility is not equipped with a flue gas desulfurization unit. The continuous emission monitoring systems shall comply with Regulation 401 KAR 61:005, Section 3, particularly, performance specification 2 of Appendix B to 40 CFR 60 or 40 CFR 75, Appendix A.

b) In accordance with Regulation 401 KAR 61:015, Section 6 (1), the sulfur content of solid fuels, as burned shall be determined in accordance with methods specified by the Division.

c) In accordance with Regulation 401 KAR 61:015, Section 6 (3) the rate of each fuel burned shall be measured daily and recorded. The heating value and ash content of fuels shall be ascertained at least once per week and recorded. The average electrical output, and the minimum and maximum hourly generation rate shall be measured and recorded daily.

d) Pursuant to Regulation 401 KAR 50:035, Section 7(1)(c), to meet the periodic monitoring requirement for particulate, the permittee shall use a continuous opacity monitor (COM). Excluding the startup and shut down periods, if any six-minute average opacity value exceeds the opacity standard, the permittee shall, as appropriate, initiate an inspection of the control equipment and/or the COM system and make any necessary repairs. If five (5) percent or greater of COM data (excluding startup, shut down, and malfunction periods, data averaged over six minute period) recorded in a calendar quarter show excursions above the opacity standard, the permittee shall perform a stack test in the following calendar quarter to demonstrate compliance with the particulate standard while operating at representative conditions. The permittee shall submit a compliance test protocol as required by condition Section G(a)(19) of this permit before conducting the test. The Division may waive this testing requirement upon a demonstration that the cause(s) of the excursions have been corrected, or may require stack tests at any time pursuant to Regulation 401 KAR 50:045, Performance tests.

e) Pursuant to Regulation 401 KAR 50:035, Section 7(1)(c), to meet the periodic monitoring requirement for opacity, the permittee shall use a continuous opacity monitor (COM). Excluding the startup and shut down periods, if any six-minute average opacity value exceeds the opacity standard, the permittee shall, as appropriate, initiate an inspection of the control equipment and/or COM system and make any necessary repairs. If visible emissions from the stack are perceived or believed to exceed the applicable standard, the permittee shall determine the opacity of emissions by Reference Method 9. If a Method 9 cannot be performed, the reason for not performing the test shall be documented.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

f) Pursuant to Regulation 401 KAR 50:035, Section 7(1)(c), to meet the periodic monitoring requirement for sulfur dioxide, the permittee shall use a continuous emission monitor (CEM) Excluding the startup and shut down periods, if any 24-hour average sulfur dioxide value exceeds the standard, the permittee shall, as appropriate, initiate an investigation of the cause of the exceedance and/or the CEM system and make any necessary repairs or take corrective actions as soon as practicable.

g) Pursuant to Regulation 401 KAR 61:005, Section 3, a continuous monitoring system for opacity shall conform to requirements of this section which include installing, calibrating, operating, and maintaining the continuous monitoring system for accurate opacity measurement, and demonstrating compliance with the applicable Performance Specification 1 of 40 CFR 60, Appendix B.

h) Pursuant to Regulation 401 KAR 61:005, Section 3(5), the Division may provide a temporary exemption from the monitoring and reporting requirements of Regulation 401 KAR 61:005, Section 3, for the continuous monitoring system during any period of monitoring system malfunction, provided that the source owner or operator shows, to the Division's satisfaction, that the malfunction was unavoidable and is being repaired as expeditiously as practicable.

5. Specific Record Keeping Requirements:

a) Records shall be kept in accordance with Regulations 401 KAR 61:005, Section 3(16) (f) and 61:015, Section 6, with the exception that the records shall be maintained for a period of five (5) years. Percentage of the COM data (excluding startup, shut down, and malfunction data) showing excursions above the opacity standard in each calendar quarter shall be computed and recorded.

b) The permittee shall maintain the results of all compliance tests.

6. Specific Reporting Requirements:

a) Pursuant to Regulation 401 KAR 61:005, Section 3 (16), minimum data requirements which follow shall be maintained and furnished in the format specified by the Division.

1. Owners or operators of facilities required to install continuous monitoring systems for opacity and sulfur dioxide or those utilizing fuel sampling and analysis for sulfur dioxide emissions shall submit for every calendar quarter, a written report of excess emissions and the nature and cause of the excess emissions if known. The averaging period used for data reporting should correspond to the emission standard averaging period which is a twenty-four (24) hour averaging period. All quarterly reports shall be postmarked by the thirtieth (30th) day following the end of each calendar quarter.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

2. For opacity measurements, the summary shall consist of the magnitude in actual percent opacity of six (6) minute averages of opacity greater than the opacity standard in the applicable standard for each hour of operation of the facility. Average values may be obtained by integration over the averaging period or by arithmetically averaging a minimum of four (4) equally spaced, instantaneous opacity measurements per minute. Any time period exempted shall be considered before determining the excess average of opacity.
3. For gaseous measurements the summary shall consist of hourly averages in the units of the applicable standard.
4. The date and time identifying each period during which the continuous monitoring system was inoperative, except for zero and span checks, and the nature of system repairs or adjustments shall be reported. Proof of continuous monitoring system performance is required as specified by the Division whenever system repairs or adjustments have been made.
5. When no excess emissions have occurred and the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be included in the report.
- b) The permittee shall report the number of excursions (excluding startup, shut down, malfunction data) above the opacity standard, date and time of excursions, opacity value of the excursions, and percentage of the COM data showing excursions above the opacity standard in each calendar quarter.

7. Specific Control Equipment Operating Conditions:

- a) The electrostatic precipitator shall be operated as necessary to maintain compliance with permitted emission limitations, in accordance with manufacturer's specifications and/or good operating practices.
- b) Records regarding the maintenance of the electrostatic precipitator shall be maintained.
- c) See Section E for further requirements.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

Emissions Unit 02 (02) - Indirect Heat Exchanger (Unit 2)

Description:

Pulverized coal-fired, dry-bottom, wall-fired unit equipped with electrostatic precipitator and low NO_x burners

Number two fuel oil used for startup and stabilization

Maximum continuous rating: 2089 mmBTU/hr

Construction commenced: 1969

Applicable Regulations:

Regulation 401 KAR 61:015, Existing indirect heat exchangers applicable to an emission unit with a capacity more than 250 MMBTU per hour and commenced before August 17, 1971. Regulation 7, Prevention and control of emissions of particulate matter from combustion of fuel in indirect heat exchangers.

1. Operating Limitations:

None

2. Emission Limitations:

- a) Pursuant to Regulation 401 KAR 61:015, Section 4 (4), and Regulation No. 7, particulate emissions shall not exceed 0.293 lb/MMBTU based on a three-hour average.
- b) Pursuant to Regulation 401 KAR 61:015, Section 4 (4), Regulation No. 7, emissions shall not exceed 40 percent opacity based on a six-minute average except that a maximum of 60 percent opacity is allowed for a period or aggregate of periods not more than six minutes in any 60 minutes during building a new fire, cleaning the firebox, or blowing soot.
- c) Pursuant to Regulation 401 KAR 61:015, Section 5 (1), sulfur dioxide emission shall not exceed 3.3 lbs/MMBTU based on a twenty-four-hour average.

3. Testing Requirements:

- a) The permittee shall submit a schedule within six months from the issuance date of this permit to conduct at least one performance test for particulate within one year following the issuance of this permit.
- b) If no additional stack tests are performed pursuant to Condition 4. d), the permittee shall conduct a performance test for particulate emissions within the third year of the term of this permit to demonstrate compliance with the applicable standard.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

c) The permittee shall determine the opacity of emissions from the stack by EPA Reference Method 9 annually, or more frequently if requested by the Division.

4. Specific Monitoring Requirements:

a) Pursuant to Regulation 401 KAR 61:005, Section 3 and Regulation 401 KAR 50:035, Section 7(1)(c), continuous emission monitoring systems shall be installed, calibrated, maintained, and operated for measuring sulfur dioxide emissions and either oxygen or carbon dioxide emissions. Or pursuant to Regulation 401 KAR 50:035, Section 7(1)(c) and Regulation 401 KAR 61:015, Section 6(6), monitoring of operations for sulfur dioxide emissions shall be conducted daily by fuel sampling and analysis of fuel as fired if the affected facility is not equipped with a flue gas desulfurization unit. The continuous emission monitoring systems shall comply with Regulation 401 KAR 61:005, Section 3, particularly, performance specification 2 of Appendix B to 40 CFR 60 or 40 CFR 75, Appendix A.

b) In accordance with Regulation 401 KAR 61:015, Section 6 (1), the sulfur content of solid fuels, as burned shall be determined in accordance with methods specified by the Division.

c) In accordance with Regulation 401 KAR 61:015, Section 6 (3) the rate of each fuel burned shall be measured daily and recorded. The heating value and ash content of fuels shall be ascertained at least once per week and recorded. The average electrical output, and the minimum and maximum hourly generation rate shall be measured and recorded daily.

d) Pursuant to Regulation 401 KAR 50:035, Section 7(1)(c), to meet the periodic monitoring requirement for particulate, the permittee shall use a continuous opacity monitor (COM). Excluding the startup and shut down periods, if any six-minute average opacity value exceeds the opacity standard, the permittee shall, as appropriate, initiate an inspection of the control equipment and/or the COM system and make any necessary repairs. If five (5) percent or greater of COM data (excluding startup, shut down, and malfunction periods, data averaged over six minute period) recorded in a calendar quarter show excursions above the opacity standard, the permittee shall perform a stack test in the following calendar quarter to demonstrate compliance with the particulate standard while operating at representative conditions. The permittee shall submit a compliance test protocol as required by condition Section G(a)(19) of this permit before conducting the test. The Division may waive this testing requirement upon a demonstration that the cause(s) of the excursions have been corrected, or may require stack tests at any time pursuant to Regulation 401 KAR 50:045, Performance tests.

e) Pursuant to Regulation 401 KAR 50:035, Section 7(1)(c), to meet the periodic monitoring requirement for opacity, the permittee shall use a continuous opacity monitor (COM). Excluding the startup and shut down periods, if any six-minute average opacity value exceeds the opacity standard, the permittee shall, as appropriate, initiate an inspection of the control equipment and/or COM system and make any necessary repairs. If visible emissions from the stack are perceived or believed to exceed the applicable standard, the permittee shall determine the opacity of emissions by Reference Method 9. If a Method 9 cannot be performed, the reason for not performing the test shall be documented.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

f) Pursuant to Regulation 401 KAR 50:035, Section 7(1)(c), to meet the periodic monitoring requirement for sulfur dioxide, the permittee shall use a continuous emission monitor (CEM) Excluding the startup and shut down periods, if any 24-hour average sulfur dioxide value exceeds the standard, the permittee shall, as appropriate, initiate an investigation of the cause of the exceedance and/or the CEM system and make any necessary repairs or take corrective actions as soon as practicable.

g) Pursuant to Regulation 401 KAR 61:005, Section 3, a continuous monitoring system for opacity shall conform to requirements of this section which include installing, calibrating, operating, and maintaining the continuous monitoring system for accurate opacity measurement, and demonstrating compliance with the applicable Performance Specification 1 of 40 CFR 60, Appendix B.

h) Pursuant to Regulation 401 KAR 61:005, Section 3(5), the Division may provide a temporary exemption from the monitoring and reporting requirements of Regulation 401 KAR 61:005, Section 3, for the continuous monitoring system during any period of monitoring system malfunction, provided that the source owner or operator shows, to the Division's satisfaction, that the malfunction was unavoidable and is being repaired as expeditiously as practicable.

5. Specific Record Keeping Requirements:

a) Records shall be kept in accordance with Regulations 401 KAR 61:005, Section 3(16) (f) and 61:015, Section 6, with the exception that the records shall be maintained for a period of five (5) years. Percentage of the COM data (excluding startup, shut down, and malfunction data) showing excursions above the opacity standard in each calendar quarter shall be computed and recorded.

b) The permittee shall maintain the results of all compliance tests.

6. Specific Reporting Requirements:

a) Pursuant to Regulation 401 KAR 61:005, Section 3 (16), minimum data requirements which follow shall be maintained and furnished in the format specified by the Division.

1. Owners or operators of facilities required to install continuous monitoring systems for opacity and sulfur dioxide or those utilizing fuel sampling and analysis for sulfur dioxide emissions shall submit for every calendar quarter, a written report of excess emissions and the nature and cause of the excess emissions if known. The averaging period used for data reporting should correspond to the emission standard averaging period which is a twenty-four (24) hour averaging period. All quarterly reports shall be postmarked by the thirtieth (30th) day following the end of each calendar quarter.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

2. For opacity measurements, the summary shall consist of the magnitude in actual percent opacity of six (6) minute averages of opacity greater than the opacity standard in the applicable standard for each hour of operation of the facility. Average values may be obtained by integration over the averaging period or by arithmetically averaging a minimum of four (4) equally spaced, instantaneous opacity measurements per minute. Any time period exempted shall be considered before determining the excess average of opacity.
3. For gaseous measurements the summary shall consist of hourly averages in the units of the applicable standard.
4. The date and time identifying each period during which the continuous monitoring system was inoperative, except for zero and span checks, and the nature of system repairs or adjustments shall be reported. Proof of continuous monitoring system performance is required as specified by the Division whenever system repairs or adjustments have been made.
5. When no excess emissions have occurred and the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be included in the report.
- b) The permittee shall report the number of excursions (excluding startup, shut down, malfunction data) above the opacity standard, date and time of excursions, opacity value of the excursions, and percentage of the COM data showing excursions above the opacity standard in each calendar quarter.

7. Specific Control Equipment Operating Conditions:

- a) The electrostatic precipitator shall be operated as necessary to maintain compliance with permitted emission limitations, in accordance with manufacturer's specifications and/or good operating practices.
- b) Records regarding the maintenance of the electrostatic precipitator shall be maintained.
- c) See Section E for further requirements.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

Emissions Unit 03 (03) - Coal Handling Operations

Description:

Equipment includes: Truck and railcar unloading, receiving hopper, coal conveyers, reclaim hoppers, crusher, coal stacker, coal stockpile, haul road, and yard area.

Operating rate: 600 tons/hr

Construction commenced : Prior 1970

APPLICABLE REGULATIONS:

Regulation 401 KAR 63:010, Fugitive emissions.

Applicable Requirements:

- a) Pursuant to Regulation 401 KAR 63:010, Section 3, reasonable precautions shall be taken to prevent particulate matter from becoming airborne. Such reasonable precautions shall include, when applicable, but not be limited to the following:
 - 1. application and maintenance of asphalt, water, or suitable chemicals on roads, material stockpiles, and other surfaces which can create airborne dusts;
 - 2. installation and use of hoods, fans, and fabric filters to enclose and vent the handling of dusty materials, or the use of water sprays or other measures to suppress the dust emissions during handling;
- b) Pursuant to Regulation 401 KAR 63:010, Section 3, discharge of visible fugitive dust emissions beyond the property line is prohibited.

1. Operating Limitations:

None

2. Emission Limitations:

None

3. Testing Requirements:

None

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

4. Specific Monitoring Requirements:

The permittee shall monitor the amount of coal received and processed.

5. Specific Record Keeping Requirements:

Records of the coal received and processed shall be maintained.

6. Specific Reporting Requirements:

See Section F.

7. Specific Control Equipment Operating Conditions:

- a) The control equipment (including but not limited to hoods, enclosures, drop chute, water truck, sweeper, and water spray system) shall be operated as necessary to maintain compliance with applicable requirements in accordance with manufacturer's specifications and/or standard engineering practices.
- b) Records regarding the maintenance of the control equipment shall be maintained.
- c) See Section E for further requirements.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

Emissions Unit 05 (-) Two Fly Ash Silos (pneumatic loading)

Description:

Maximum operating rate: 31 tons/hr, each.

Construction commenced: 1993

APPLICABLE REGULATIONS:

Regulation 401 KAR 59:010, New process operations applicable to emission units commenced on or after July 2, 1975.

1. Operating Limitations:

None

2. Emission Limitations:

- a) Pursuant to Regulation 401 KAR 59:010, Section 3(2), particulate matter emissions into the open air shall not exceed $[17.31 (P)^{0.16}]$ lbs/hour based on a three-hour average where P is the processing rate in tons per hour.
- b) Pursuant to Regulation 401 KAR 59:010, Section 3(1)(a), visible emissions from any stack shall not equal or exceed twenty (20) percent opacity based on a six-minute average.

3. Testing Requirements:

The permittee shall determine the opacity of emissions from each stack by EPA Reference Method 9 annually, or more frequently if requested by the Division.

4. Specific Monitoring Requirements:

- a) The permittee shall perform a qualitative visual observation of the opacity of emissions from each stack on a weekly basis and maintain a log of the observations. If emissions from any stack are perceived or believed to exceed the applicable standard, the permittee should log that in the record, and determine the opacity of emissions by Reference Method 9 and instigate an inspection of the control equipment for any necessary repairs.
- b) The permittee shall monitor the processing rate and hours of operation on a weekly basis.

5. Specific Record Keeping Requirements:

Records of the weekly ash processed and weekly hours of operation shall be maintained.

6. Specific Reporting Requirements:

See Section F.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

7. Specific Control Equipment Operating Conditions:

- a) The baghouses shall be operated as necessary to maintain compliance with permitted emission limitations, in accordance with manufacturer's specifications and / or standard operating practices.
- b) Records regarding the maintenance of the baghouses shall be maintained.
- c) See Section E for further requirements.

SECTION B - EMISSION POINTS, EMISSIONS UNITS, APPLICABLE REGULATIONS, AND OPERATING CONDITIONS (Continued)

Emissions Unit 07 (-) Coal Crushing Facilities

Description:

Equipment includes: A & T Model 425 Feeder, Crusher Feeder Conveyor, Jeffrey Model 59FT Flextooth Crusher, Crushed Coal Conveyor and Discharge Chute.

Operating rate: 400 tons per hour

Construction commenced: December, 1998

Applicable Regulations:

Regulation 401 KAR 60:250, Standards of performance for coal preparation plants, incorporating by reference 40 CFR 60 Subpart Y for emissions units commenced after October 24, 1974

1. Operating Limitations:

None

2. Emission Limitations:

Pursuant to Regulation 401 KAR 60:250, 40 CFR 60.252, the owner or operator subject to the provisions of this regulation shall not cause to be discharged into the atmosphere from any coal processing and conveying equipment, coal storage system, or transfer and loading system processing coal, gases which exhibit 20 percent opacity or greater.

3. Testing Requirements:

Pursuant to Regulation 401 KAR 60:250, 40 CFR 60.254, EPA Reference Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity at least annually, or more frequently if requested by the Division.

4. Specific Monitoring Requirements:

The permittee shall perform a qualitative visual observation of the opacity of emissions from each emissions unit on a weekly basis and maintain a log of the observations. If visible emissions from any emissions units are perceived or believed to exceed the applicable standard, the permittee shall determine the opacity of emissions by Reference Method 9 and instigate an inspection of the control equipment making any necessary repairs.

5. Specific Record Keeping Requirements:

Records of the coal processed shall be maintained for emissions inventory purposes.

6. Specific Reporting Requirements:

See Section C, General Conditions

SECTION C - INSIGNIFICANT ACTIVITIES

The following listed activities have been determined to be insignificant activities for this source pursuant to Regulation 401 KAR 50:035, Section 5(4). While these activities are designated as insignificant the permittee must comply with the applicable regulation(s). Process and emission control equipment at each insignificant activity subject to a generally applicable regulation shall be inspected weekly and a qualitative visible emissions evaluation made. The results of the inspections and observations shall be recorded in a log, noting color, duration, density (heavy or light), cause and any corrective actions taken for any abnormal visible emissions.

<u>Description</u>	<u>Generally Applicable Regulation</u>
1. Storage vessels containing petroleum or organic liquids with a capacity of less than 10,567 gallons, providing (a) the vapor pressure of the stored liquid is less than 1.5 psia at storage temperature, or (b) vessels greater than 580 gallons with stored liquids having greater than 1.5 psia vapor pressure are equipped with a permanent submerged fill pipe.	NA
2. Storage vessels containing inorganic aqueous liquids, except inorganic acids with boiling points below the maximum storage temperature at atmospheric pressure.	NA
3. #2 oil-fired space heaters or ovens rated at less than two million BTU per hour actual heat input, provided the maximum sulfur content is less than 0.5% by weight.	NA
4. Machining of metals, providing total solvent usage at the source for this activity does not exceed 60 gallons per month.	NA
5. Internal combustion engines using only gasoline, diesel fuel, natural gas, or LP gas rated at 50 hp or less.	NA
6. Volatile organic compound and hazardous air pollutant storage containers, as follows: (a) Tanks, less than 1,000 gallons, and throughput less than 12,000 gallons per year; (b) Lubricating oils, hydraulic oils, machining oils, and machining fluids.	NA

SECTION C - INSIGNIFICANT ACTIVITIES (Continued)

	<u>Description</u>	<u>Generally Applicable Regulation</u>
7.	Machining where an aqueous cutting coolant continuously floods machining interface.	NA
8.	Degreasing operations, using less than 145 gallons per year.	NA
9.	Maintenance equipment, not emitting HAPs: brazing, cutting torches, soldering, welding.	401KAR 63:010
10.	Underground conveyors.	401KAR 63:010
11.	Coal bunker and coal scale exhausts.	NA
12.	Blowdown (sight glass, boiler, compressor, pump, cooling tower)	NA
13.	On-site fire and emergency response training.	NA
14.	Stationary fire pumps.	NA
15.	Grinding and machining operations vented through fabric filters, scrubbers, mist eliminators, or electrostatic precipitators (e.g., deburring, buffing, polishing, abrasive blasting, pneumatic conveying, woodworking)	401KAR 63:010
16.	Vents from ash transport systems not operated at positive pressure.	NA
17.	Wastewater treatment (for stream less than 1% oil and grease).	NA
18.	Sanitary sewage treatment	NA
19.	Heat exchanger cleaning and repair.	NA
20.	Equipment used exclusively for forging, pressing drawing, stamping, spinning, or extruding metals. This does not include emissions due to quenching activities.	NA

SECTION C - INSIGNIFICANT ACTIVITIES (Continued)

	<u>Description</u>	<u>Generally Applicable Regulation</u>
21.	Repair and maintenance of ESP, fabric filters, etc.	NA
22.	Railcar/truck flyash loadout	401KAR 63:010

SECTION D - SOURCE EMISSION LIMITATIONS AND TESTING REQUIREMENTS

1. Particulate, sulfur dioxide, and visible (opacity) emissions, as measured by methods referenced in Regulation 401 KAR 50:015, Section 1, shall not exceed the respective limitations specified herein.

SECTION E - CONTROL EQUIPMENT CONDITIONS

1. Pursuant to Regulation 401 KAR 50:055, Section 2(5), at all times, including periods of startup, shutdown and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice as well as in accordance with manufacturer's specifications for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Division which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.

SECTION F - MONITORING, RECORD KEEPING, AND REPORTING REQUIREMENTS

1. When continuing compliance is demonstrated by periodic testing or instrumental monitoring, the permittee shall compile records of required monitoring information that include:
 - a. Date, place as defined in this permit, and time of sampling or measurements.
 - b. Analyses performance dates;
 - c. Company or entity that performed analyses;
 - d. Analytical techniques or methods used;
 - e. Analyses results; and
 - f. Operating conditions during time of sampling or measurement;
2. Records of all required monitoring data and support information, including calibrations, maintenance records, and original strip chart recordings, and copies of all reports required by the Division for Air Quality, shall be retained by the permittee for a period of five years and shall be made available for inspection upon request by any duly authorized representative of the Division for Air Quality. [401 KAR 50:035, Permits, Section 7(1)(d)2 and 401 KAR 50:035, Permits, Section 7(2)(c)]
3. In accordance with the requirements of Regulation 401 KAR 50:035, Permits, Section 7(2)(c) the permittee shall allow the Cabinet or authorized representatives to perform the following:
 - a. Enter upon the premises where a source is located or emissions-related activity is conducted, or where records are kept;
 - b. Have access to and copy, at reasonable times, any records required by the permit:
 - i. During normal office hours, and
 - ii. During periods of emergency when prompt access to records is essential to proper assessment by the Cabinet;
 - c. Inspect, at reasonable times, any facilities, equipment (including monitoring and pollution control equipment), practices, or operations required by the permit. Reasonable times shall include, but are not limited to the following:
 - i. During all hours of operation at the source,
 - ii. For all sources operated intermittently, during all hours of operation at the source and the hours between 8:00 a.m. and 4:30 p.m., Monday through Friday, excluding holidays, and
 - iii. During an emergency; and
 - d. Sample or monitor, at reasonable times, substances or parameters to assure compliance with the permit or any applicable requirements. Reasonable times shall include, but are not limited to the following:
 - i. During all hours of operation at the source,
 - ii. For all sources operated intermittently, during all hours of operation at the source and the hours between 8:00 a.m. and 4:30 p.m., Monday through Friday, excluding holidays, and
 - iii. During an emergency.
4. No person shall obstruct, hamper, or interfere with any Cabinet employee or authorized representative while in the process of carrying out official duties. Refusal of entry or access may constitute grounds for permit revocation and assessment of civil penalties.

SECTION F - MONITORING, RECORD KEEPING, AND REPORTING REQUIREMENTS (CONTINUED)

5. Summary reports of any monitoring required by this permit shall be submitted to the Division's London Regional Office at least every six (6) months during the life of this permit, unless otherwise stated in this permit. The reports are due within 30 days after the end of each six month reporting period which commences on the initial issuance date of this permit. The permittee may shift to semi-annual reporting on a calendar year basis upon approval of the regional office. If calendar year reporting is approved, the semi-annual reports are due January 30th and July 30th of each year. All reports shall be certified by a responsible official pursuant to Section 6(1) of Regulation 401 KAR 50:035, Permits. All deviations from permit requirements shall be clearly identified in the reports.
6.
 - a. In accordance with the provisions of Regulation 401 KAR 50:055, Section 1 the owner or operator shall notify the Division for Air Quality's London Regional Office concerning startups, shutdowns, or malfunctions as follows:
 1. When emissions during any planned shutdowns and ensuing startups will exceed the standards notification shall be made no later than three (3) days before the planned shutdown, or immediately following the decision to shut down, if the shutdown is due to events which could not have been foreseen three (3) days before the shutdown.
 2. When emissions due to malfunctions, unplanned shutdowns and ensuing startups are or may be in excess of the standards notification shall be made as promptly as possible by telephone (or other electronic media) and shall cause written notice upon request.
 - b. In accordance with the provisions of Regulation 401 KAR 50:035, Section 7(1)(e)2, the owner or operator shall promptly report deviations from permit requirements including those attributed to upset conditions (other than emission exceedances covered by general condition 6 a. above) to the Division for Air Quality's London Regional Office. Prompt reporting shall be defined as quarterly for any deviation related to emission standards (other than emission exceeding covered by general condition 6(a) above) and semi-annually for all other deviations from the permit requirements if not otherwise specified in the permit.
7. Pursuant to Regulation 401 KAR 50:035, Permits, Section 7(2)(b), the permittee shall certify compliance with the terms and conditions contained in this permit, annually on the permit issuance anniversary date or by January 30th of each year if calendar year reporting is approved by the regional office, by completing and returning a Compliance Certification Form (DEP 7007CC) (or an approved alternative) to the Division for Air Quality's London Regional Office and the U.S. EPA in accordance with the following requirements:
 - a. Identification of each term or condition of the permit that is the basis of the certification;
 - b. The compliance status regarding each term or condition of the permit;
 - c. Whether compliance was continuous or intermittent; and
 - d. The method used for determining the compliance status for the source, currently and over the reporting period, pursuant to 401 KAR 50:035, Section 7(1)(c),(d), and (e).

SECTION F - MONITORING, RECORD KEEPING, AND REPORTING REQUIREMENTS (CONTINUED)

- e. The certification shall be postmarked by the thirtieth (30) day following the applicable permit issuance anniversary date, or by January 30th of each year if calendar year reporting is approved by the regional office. Annual compliance certifications should be mailed to the following addresses:

**Division for Air Quality
London Regional Office
85 State Police Road
Reg. Street Office Building
London, Kentucky 40741-9008**

**U.S. EPA Region IV
Air Enforcement Branch
Atlanta Federal Center
61 Forsyth St.
Atlanta, GA 30303-8960**

**Division for Air Quality
Central Files
803 Schenkel Lane
Frankfort, KY 40601**

8. In accordance with Regulation 401 KAR 50:035, Section 23, the permittee shall provide the division with all information necessary to determine its subject emissions within thirty (30) days of the date the KEIS emission report is mailed to the permittee.
9. Pursuant to Section VII.3 of the policy manual of the Division for Air Quality as referenced by Regulation 401 KAR 50:016, Section 1(1), results of performance test(s) required by the permit shall be submitted to the division by the source or its representative within forty-five days after the completion of the fieldwork.

SECTION G - GENERAL CONDITIONS**(a) General Compliance Requirements**

1. The permittee shall comply with all conditions of this permit. A noncompliance shall be (a) violation(s) of state regulation 401 KAR 50:035, Permits, Section 7(3)(d) and for federally enforceable permits is also a violation of Federal Statute 42 USC 7401 through 7671q (the Clean Air Act) and is grounds for enforcement action including but not limited to the termination, revocation and reissuance, or revision of this permit.
2. The filing of a request by the permittee for any permit revision, revocation, reissuance, or termination, or of a notification of a planned change or anticipated noncompliance, shall not stay any permit condition.
3. This permit may be revised, revoked, reopened and reissued, or terminated for cause. The permit will be reopened for cause and revised accordingly under the following circumstances:
 - a. If additional applicable requirements become applicable to the source and the remaining permit term is three (3) years or longer. In this case, the reopening shall be completed no later than eighteen (18) months after promulgation of the applicable requirement. A reopening shall not be required if compliance with the applicable requirement is not required until after the date on which the permit is due to expire, unless this permit or any of its terms and conditions have been extended pursuant to Regulation 401 KAR 50:035, Section 12(2)(c);
 - b. The Cabinet or the U. S. EPA determines that the permit must be revised or revoked to assure compliance with the applicable requirements;
 - c. The Cabinet or the U. S. EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit;
 - d. If any additional applicable requirements of the Acid Rain Program become applicable to the source.

Proceedings to reopen and reissue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Reopenings shall be made as expeditiously as practicable. Reopenings shall not be initiated before a notice of intent to reopen is provided to the source by the division, at least thirty (30) days in advance of the date the permit is to be reopened, except that the division may provide a shorter time period in the case of an emergency.

4. The permittee shall furnish to the division, in writing, information that the division may request to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. [401 KAR 50:035, Permits, Section 7(2)(b)3e and 401 KAR 50:035, Permits, Section 7(3)(j)]
5. The permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information to the permitting authority.

SECTION G - GENERAL CONDITIONS (CONTINUED)

6. Any condition or portion of this permit which becomes suspended or is ruled invalid as a result of any legal or other action shall not invalidate any other portion or condition of this permit. [401 KAR 50:035, Permits, Section 7(3)(k)]
7. The permittee shall not use as a defense in an enforcement action the contention that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance. [401 KAR 50:035, Permits, Section 7(3)(e)]
8. Except as identified as state-origin requirements in this permit, all terms and conditions contained herein shall be enforceable by the United States Environmental Protection Agency and citizens of the United States.
9. This permit shall be subject to suspension if the permittee fails to pay all emissions fees within 90 days after the date of notice as specified in 401 KAR 50:038, Section 3(6). [401 KAR 50:035, Permits, Section 7(3)(h)]
10. Nothing in this permit shall alter or affect the liability of the permittee for any violation of applicable requirements prior to or at the time of permit issuance. [401 KAR 50:035, Permits, Section 8(3)(b)]
11. This permit shall not convey property rights or exclusive privileges. [401 KAR 50:035, Permits, Section 7 (3)(g)]
12. Issuance of this permit does not relieve the permittee from the responsibility of obtaining any other permits, licenses, or approvals required by the Kentucky Cabinet for Natural Resources and Environmental Protection or any other federal, state, or local agency.
13. Nothing in this permit shall alter or affect the authority of U.S. EPA to obtain information pursuant to Federal Statute 42 USC 7414, Inspections, monitoring, and entry. [401 KAR 50:035 , Permits, Section 7(2)(b)5]
14. Nothing in this permit shall alter or affect the authority of U.S. EPA to impose emergency orders pursuant to Federal Statute 42 USC 7603, Emergency orders. [401 KAR 50:035, Permits, Section 8(3)(a)]
15. Permit Shield: Except as provided in State Regulation 401 KAR 50:035, Permits, compliance by the emissions units listed herein with the conditions of this permit shall be deemed to be compliance with all applicable requirements identified in this permit as of the date of issuance of this permit.
16. All previously issued construction and operating permits are hereby null and void.

SECTION G - GENERAL CONDITIONS (CONTINUED)

17. The permittee may conduct test burns of materials other than those listed in the permit without a construction permit or a reopening of this permit provided that:
 - a) Notification is provided to the Division at least 30 days prior to initiation of the test burning of the material;
 - b) The source complies with all applicable regulations and emission limitations;
 - c) The permittee agrees to perform such additional testing as may be required by the Division;
18. The permanent burning of any materials (addressed in above condition) shall be allowed upon completion of testing provided that :
 - a) The Division determines that a permit is not required. Such determination shall be made within sixty (60) days of the application receipt along with the test result;
 - b) The permittee keep records of date and time of burn;
 - c) The permittee keeps records of analysis and feed rate of material;
 - b) Burning any of those materials shall not be subject to any applicable regulation and the source shall comply with all applicable regulation and emission limitations.
19. Fugitive emissions shall be controlled in accordance with Regulation 401 KAR 63:010.
20. Emission limitations listed in this permit shall apply at all times except during periods of startup, shutdown, or malfunctions, and opacity limitations listed in this permit shall apply at all times except during periods of startup and shutdown in accordance with Regulation 401 KAR 50:055, provided the permittee complies with the requirements of Regulation 401 KAR 50:055.
21. Pursuant to Section VII 2.(1) of the policy manual of the Division for Air Quality as referenced by regulation 401 KAR 50:016, Section 1(1), at least one month prior to the date of the required performance test, the permittee shall complete and return a Compliance Test Protocol(Form DEP 6027) to the Division's Frankfort Central Office. Pursuant to Regulation 401 KAR 50:045, Section 5, the Division shall be notified of the actual test date at least ten (10) days prior the test.

(b) Permit Expiration and Reapplication Requirements

This permit shall remain in effect for a fixed term of five (5) years following the original date of issue. Permit expiration shall terminate the source's right to operate unless a timely and complete renewal application has been submitted to the division at least six months prior to the expiration date of the permit. Upon a timely and complete submittal, the authorization to operate within the terms and conditions of this permit, including any permit shield, shall remain in effect beyond the expiration date, until the renewal permit is issued or denied by the division. [401 KAR 50:035, Permits, Section 12]

SECTION G - GENERAL CONDITIONS (CONTINUED)

(c) Permit Revisions

1. A minor permit revision procedure may be used for permit revisions involving the use of economic incentive, marketable permit, emission trading, and other similar approaches, to the extent that these minor permit revision procedures are explicitly provided for in the SIP or in applicable requirements and meet the relevant requirements of Regulation 401 KAR 50:035, Section 15.
2. This permit is not transferable by the permittee. Future owners and operators shall obtain a new permit from the Division for Air Quality. The new permit may be processed as an administrative amendment if no other change in this permit is necessary, and provided that a written agreement containing a specific date for transfer of permit responsibility coverage and liability between the current and new permittee has been submitted to the permitting authority thirty (30) days in advance of the transfer.

(d) Acid Rain Program Requirements

1. If an applicable requirement of Federal Statute 42 USC 7401 through 7671q (the Clean Air Act) is more stringent than an applicable requirement promulgated pursuant to Federal Statute 42 USC 7651 through 7651o (Title IV of the Act), both provisions shall apply, and both shall be state and federally enforceable.
2. The source shall comply with all requirements and conditions of the Title IV Acid Rain Permit(A-98-012, attached) issued for this source. The source shall also comply with all requirements of any revised or future acid rain permit(s) issued to this source.

(e) Emergency Provisions

1. An emergency shall constitute an affirmative defense to an action brought for noncompliance with the technology-based emission limitations if the permittee demonstrates through properly signed contemporaneous operating logs or other relevant evidence that:
 - a. An emergency occurred and the permittee can identify the cause of the emergency;
 - b. The permitted facility was at the time being properly operated;
 - c. During an emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements in the permit; and,
 - d. The permittee notified the division as promptly as possible and submitted written notice of the emergency to the division within two working days after the time when emission limitations were exceeded due to the emergency. The notice shall meet the requirements of 401 KAR 50:035, Permits, Section 7(1)(e)2, and include a description of the emergency, steps taken to mitigate emissions, and the corrective actions taken. This requirement does not relieve the source of any other local, state or federal notification requirements.

SECTION G - GENERAL CONDITIONS (CONTINUED)

2. Emergency conditions listed in General Condition (f)1 above are in addition to any emergency or upset provision(s) contained in an applicable requirement.
3. In an enforcement proceeding, the permittee seeking to establish the occurrence of an emergency shall have the burden of proof. [401 KAR 50:035, Permits, Section 9(3)]

(f). Risk Management Provisions

1. The permittee shall comply with all applicable requirements of 40 CFR Part 68, Risk Management Plan provisions. If required, the permittee shall:
 - a. Submit a Risk Management Plan to U.S.EPA, Region IV with a copy to this division and comply with the Risk Management Program by June 21, 1999 or a later date specified by the U.S.EPA.
 - b. Submit additional relevant information if requested by the division or the U.S. EPA.

(g). Ozone Depleting Substances

1. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR 82, Subpart F, except as provided for Motor Vehicle Air Conditioners (MVACs) in Subpart B:
 - a. Persons opening appliances for maintenance, service, repair, or disposal shall comply with the required practices contained in 40 CFR 82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliances shall comply with the standards for recycling and recovery equipment contained in 40 CFR 82.158.
 - c. Persons performing maintenance, service, repair, or disposal of appliances shall be certified by an approved technician certification program pursuant to 40 CFR 82.161.
 - d. Persons disposing of small appliances, MVACs, and MVAC-like appliances (as defined at 40 CFR 82.152) shall comply with the recordkeeping requirements pursuant to 40 CFR 82.166.
 - e. Persons owning commercial or industrial process refrigeration equipment shall comply with the leak repair requirements pursuant to 40 CFR 82.156.
 - f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant shall keep records of refrigerant purchased and added to such appliances pursuant to 40 CFR 82.166.
2. If the permittee performs service on motor (fleet) vehicle air conditioners containing ozone-depleting substances, the source shall comply with all applicable requirements as specified in 40 CFR 82, Subpart B, Servicing of Motor Vehicle Air Conditioners.

SECTION H - ALTERNATE OPERATING SCENARIOS

None

SECTION I - COMPLIANCE SCHEDULE

None